

## Annexure C

### PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 6428 / जल परीक्षण / 39 Dated: 25/06/2025

It is certified that an inspection team headed by **Sunil Kumar Singh (Assistant Engineer)**

(Name of Officers with designation) from **UP Jal Nigam (Rural), Mirzapur,**

inspected the **Dr. Sarla Sarraf Public School Vijaypura, Bhatauli Road, Mirzapur- Uttar Pradesh 231001,**

**India** (Name & Address of the school) on **24/06/2025** (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. **MBC7793** dated **24/06/2025**

of District Level Water Analysis Laboratory UP Jal Nigam, (Rural) Mirzapur-UP (India) (PHED Lab) certified that


the **Dr. Sarla Sarraf Public School** (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till **6 Months**

Signature with Seal: 

Name : Sunil Kumar Singh

Designation : A.E.

Name & Address of the Office / Department : सहायक अभियन्ता  
जल कार्यलय, उ० प्र० जल निगम (ग्रामीण)  
मीरजापुर

To

**Dr. Sarla Sarraf Public School**  
**Vijaypura, Bhatauli Road, Mirzapur- Uttar Pradesh 231001, India**

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



# Analysis Report

District Level Water Analysis Laboratory  
U.P Jal Nigam (Rural), Mirzapur, (Uttar Pradesh)- India



Rept No	MBC7793	Date	24-06-2025	Page No.	1
---------	---------	------	------------	----------	---

## Customer Details

Office Name and Address of the Customer	Dr. Sarla Sarraf Public School Vijaypura, Bhatauli Road, Mirzapur- Uttar Pradesh 231001, India
-----------------------------------------	---------------------------------------------------------------------------------------------------

## Basic details of sample

State	Uttar Pradesh	Block	City
District	Mirzapur	Village/Mohalla	Vijaypura
Gram Panchayat	Vijaypura	Location/Site Name	Dinesh Chandra Sarraf
Habitation	-	Sample No.	1
Water Source	Submersible	Date of Sample Collection	21-06-2025
Quantity of Sample	1000 ml	Sample Collector	Mahendra Gupta
Receiving Date	21-06-2025		
Sample Depositer	Mahendra Gupta		
Analysis Start Date	23-06-2025	Analysis Completion Date	24-06-2025

## Environmental Condition

Temperature	25.4°C	Relative Humidity	56%
-------------	--------	-------------------	-----

## Technical Data of Analysis

S.No.	Analysed Parameter	Units	Observed Value	Specified Values as per IS 10500:2012		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit	
1	2	3	4	5	6	7
1	Colour	Hazen	5	5	15	APHA 24th Edition-2120- color method B (Platinum Cobalt Visual Comparison method): 2023
2	Odour	Qualitative	Aggreable	-	-	IS 3025 (Part 5):2022: 2022
3	Taste	Qualitative	Aggreable	-	-	IS 3025 (Part 8): 2023: 2023
4	pH	-	7.39	6.5-8.5	6.5-8.5	IS 3025 (Part 11): 2022 (Electrometric Method)
5	Turbidity	(NTU)	2.46	1.00	5.00	Apha 24th Edition-2130 -turbidity method B: 2023
6	TDS	(mg/L)	465.27	500	2000	IS 3025 (Part 16) : 2023
7	Chloride	(mg/L)	32.5	250	1000	APHA 24th Edition -4500-Cl Method B (Argentometric method): 2023
8	Total Alkalinity	(mg/L)	355	200	600	IS 3025 (Part 23) : 2023
9	Total Hardness	(mg/L)	340	200	600	IS 3025 (Part 21) : 2019
10	Sulphate	(mg/L)	9.99	200	400	APHA 24th Edition -4500-SO4 Method E (Turbidimetric Method): 2023
11	Nitrate	(mg/L)	34.13	45	45	APHA 24th Edition -4500- NO3 Method B (UV Screening Method): 2023
12	Fluoride	(mg/L)	0.825	1	1.5	APHA 24th Edition -4500-F Method C (Electrode Method) : 2023
13	Iron	(mg/L)	0.19	1.0	1.0	APHA 24th Edition -3500-Fe Method B (Phenanthroline Method) : 2023
14	Calcium	(mg/L)	46.092	75	200	IS 3025 (Part 40) :2023
15	Magnessium	(mg/L)	54.675	30	100	APHA 24th Edition -3500-Mg Method B (By Calculation): 2023

## Note

1. This Certificate refers only to the particular sample(s) submitted for testing.
2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
4. The sample has not been collected by the lab, hence the entire responsibility of sample collection lies with the sample collector.
5. Sample will be stored up to 07 days (in case of non perishable items only) from the date of issue of tests reports unless otherwise specified.
6. It is hereby informed that the parameters shown in bold in this test report have exceeded the permissible limits and are therefore identified as contaminated.
7. BDL:- Below Detection Limit.
8. UDL:- Upper Detection Limit.

Prepared By

Reviewed By

Authorized Signatory


(Pradeep Kumar Saroj)  
Data Entry Operator

(Ajit Kumar Pandey)  
Lab Assistant

(Avinash Kumar Singh)  
Lab incharge/Quality Manager/Technical Manager/Chemist

Laboratory Contact details-Email ID:-labmirzapur@gmail.com, Mob-7004603349/9955720321

End of the Report





# Analysis Report

District Level Water Analysis Laboratory  
U.P Jal Nigam (Rural), Mirzapur, (Uttar Pradesh)- India

Report No.-

MBC7793

Date of Testing:-

24-06-2025

## Technical Data of Microbiological Analysis

S.No.	Analysed Parameter	Units	Observed Value	Specified Values		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit	
1	2	3	4	5	6	7
1	Total Coliform	Presumptive	Absent	Absent	Absent	H2S Vial (Presumptive Test)
2	E.coli	Presumptive	Absent	Absent	Absent	H2S Vial (Presumptive Test)
3	Free Residual Chlorine	mg/l	0.0	0.2	1.0	DPD Method

### Note

1. This Certificate refers only to the particular sample(s) submitted for testing.
2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
4. Sample will be stored up to 07 days (in case of non perishable items only) from the date of issue of tests reports unless otherwise specified.
5. The sample has not been collected by the lab, hence the entire responsibility of sample collection lies with the sample collector
6. "The complete address/Basic details associated with microbiological test report number MBC7686 is provided on the reverse side of the document."

**Tested and Approved By**

  
Aditya Anuj Singh  
(Microbiologist)

Laboratory Contact details-Email-labmirzapur@gmail.com, Mob-7004603349/9955720321